

PRODUCT PERFORMANCE RATING

Document ID 1632563252-9d-e7200520

Issued on: 25 September 2021 - *Dé livré le : 25 septembre 2021*

This product is certified by Eurovent Certita Certification as mentioned on:
Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

Certificate N° 17.02.236

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

Certification programmes / *Programmes de certification*

Product type / *Type de produit*

Model name / *Nom du modèle*

Eurovent Heat Pumps

Air to air, split, heating, and cooling (≤ 12 kW)

AR24TXFCWKN/AR24TXFCWXX

This performance certificate is delivered for the following project

| Project Name | Project company | Project Reference | Project location |
|----------------------|--------------------------|--------------------------|-------------------------------|
| <i>Nom du projet</i> | <i>Nom de la société</i> | <i>Project Reference</i> | <i>Localisation du projet</i> |
| RAC | AMBIENT | AMBIENT | Greece |

PRODUCT PERFORMANCE RATING

Document ID 1632563252-9d-e7200520

Issued on: 25 September 2021 - Délivré le : 25 septembre 2021

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

Certificate N° 17.02.236

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

| FEATURE | VALUE | UNIT |
|--|---------|-----------|
| Seasonal Efficiency In Cooling | | |
| Pdesignc (Design Load Cooling) | 6.5 | kW |
| SEER (Seasonal Energy Efficiency Ratio) | 6.4 | |
| Qce (Annual electricity consumption for cooling) | 355.47 | kWh/annum |
| SEER Class (Seasonal Energy Efficiency Ratio Class) | A++ | |
| Heating Average Climate | | |
| Pdesignh (Design load heating) | 4.1 | kW |
| SCOP (Reference SCOP) | 3.8 | |
| SCOP Class (Seasonal Coefficient Of Performance Class) | A | |
| Qhe (Annual electricity consumption for heating) | 1510.53 | kWh/annum |
| Acoustic | | |
| LW0 env (A-weighted sound level outdoor near the envelope for non ducted units) | 68 | dB(A) |
| Lw1 env (A-weighted sound power level indoor unit 1 (non ducted)) | 62 | dB(A) |
| Thermal | | |
| Pc (Total Cooling Capacity) | 6.5 | kW |
| Pec (Effective Power Input for Cooling (for chilled water cooled Close Control units only) | 1.95 | kW |
| EER (Energy Efficiency Ratio) | 3.33 | |
| Cooling PL CondB | | |
| Pc @ 30°C (Declared Cooling Capacity @ 30°C) | 4.8 | kW |
| EER @ 30°C (Declared Energy Efficiency @ 30°C) | 5.1 | |
| Cooling PL CondC | | |
| Pc @ 25°C (Declared Cooling Capacity @ 25°C) | 3 | kW |
| EER @ 25°C (Declared Energy Efficiency @ 25°C) | 7.4 | |
| Cooling PL CondD | | |
| Pc @ 20°C (Declared Cooling Capacity @ 20°C) | 1.6 | kW |
| EER @ 20°C (Declared Energy Efficiency @ 20°C) | 12.6 | |
| Standard Heating | | |
| Ph (Heating Capacity) | 7.4 | kW |
| Peh (Net Electric Power Consumption for Heating Only application) | 2.35 | kW |
| COP (Coefficient Of Performance) | 3.15 | |

Certificate N° 17.02.236

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

| Heating PL CondA | | |
|--|-----|----|
| Ph @ -7°C (Declared Heating Capacity @ -7°C) | 3.4 | kW |
| COP @ -7°C (Declared Coefficient Of Performances @ -7°C) | 2.8 | |
| Heating PL CondB | | |
| Ph @ +2°C (Declared Heating Capacity @ +2°C) | 2.2 | kW |
| COP @ 2°C (Declared Coefficient Of Performances @ 2°C) | 4 | |
| Heating PL CondC | | |
| Ph @ +7°C (Declared Heating Capacity @ +7°C) | 1.6 | kW |
| COP @ +7°C (Declared Coefficient Of Performances @ +7°C) | 5.3 | |
| Heating PL CondD | | |
| Ph @ +12°C (Declared Heating Capacity @ +12°C) | 1.6 | kW |
| COP @ +12°C (Declared Coefficient Of Performances @ +12°C) | 6.3 | |
| Bivalent Point | | |
| Tbiv (Bivalent Temperature) | -10 | °C |
| COP @ Tbiv (Declared coefficient of performances at bivalent temperature condition) | 2.7 | |
| Ph TBiv (Heating capacity at bivalent temperature) | 4.1 | kW |
| TOL Runing Test | | |
| TOL (Operating LimitTemperature) | -11 | °C |
| COP @ TOL (Declared Coefficient Of Performances @ TOL) | 2.7 | |
| Ph @ TOL (Declared Heating Capacity @ TOL) | 4.1 | kW |
| Heating Colder Climate | | |
| SCOP Class colder climate (Seasonal Coefficient Of Performance Class (colder climate)) | G | |
| Heating Warmer Climate | | |
| SCOP (Refrence SCOP Warmer Climate) | 4.6 | |
| SCOP Class warmer climate (Seasonal Coefficient Of Performance Class (warmer climate)) | A++ | |
| AC Poffc | | |
| Poff (Power consumption in off mode) | 3 | W |
| AC Psbc (RT2012) | | |
| Psb (Power consumption in standby mode cooling (Paux, cooling)) | 3 | W |
| AC Ptoc | | |
| Pto (Power consumption in thermostat off mode) | 40 | W |



PRODUCT PERFORMANCE RATING

Document ID 1632563252-9d-e7200520

Issued on: 25 September 2021 - *Déjà livré le : 25 septembre 2021*

This product is certified by Eurovent Certita Certification as mentioned on:

Ce produit est certifié par Eurovent Certita Certification comme mentionné sur :

Certificate N° 17.02.236

This document is valid at the date of issue - Check the current validity on www.eurovent-certification.com

Ce document est valide à la date d'édition - Vérifiez la date de validité sur www.eurovent-certification.com

| General | | |
|--|----------|---|
| Refrigerant (Refrigerant (R410A, R32, R407C, R290, etc.)) | R32 | |
| Refr. Line (Refrigerant Line. If possible) | 5 | m |
| Main Power Supply (Main Power Supply [Voltage (V) - Phase - Frequency (Hz)]) | 230-1-50 | |
| Mounting (Mounting Type) | WALL | |