A	Model(s) : AE120RXYDEG / AE200RNWMEG
B	Air-to-water heat pump : yes
C	Water-to-water heat pump : no
D	Brine-to-water heat pump : no
E	Low-temperature heat pump : no
F	Equipped with a supplementary heater : yes
G	Heat pump combination heater : yes
H	Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pump, parameters shall be declared for low-temperature application.
I	Parameters shall be declared for average climate conditions.

	Item (J)	Symbol (K)	Value (L)	Unit (M)
N	**Rated heat output(*)**	Prated (G)	12	kW
Q	**Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T j**			
-	Tj = -7 °C	Pdh	10,6	kW
-	Tj = +2 °C	Pdh	6,5	kW
-	Tj = +7 °C	Pdh	4,2	kW
-	Tj = +12 °C	Pdh	4,4	kW
T	Tj = bivalent temperature	Pdh	12,0	kW
U	Tj = operation limit temperature	Pdh	12,0	kW
V	For air-to-water heat pumps Tj = -15 °C (if TOL < -20 °C)	Pdh	-	kW
W	Bivalent temperature	Tbiv	-10	°C
Y	Cycling interval capacity for heating	Pcych	-	kW
AB	Degradation co-efficient (**)	Cdh	0,9	-
AD	**Power consumption in modes other than active mode**			
AF	Off mode	P_{OFF}	0,022	kW
AG	Thermostat-off mode	P_{TO}	0,022	kW
AH	Standby mode	P_{SB}	0,022	kW
AI	Crankcase heater mode	P_{CK}	0,000	kW
AL	**Other items**			
AM	Capacity control	variable (AN)		
AQ	Sound power level, indoors/ outdoors	L_{WA}	44/64	dB
AR	Emissions of nitrogen oxides	NOx	-	mg/kWh
AT	**For heat pump combination heater**			
AU	Declared load profile	L		
AW	Daily electricity comsumption	Q_{elec}	-	kWh
AY	Annual electricity consumption	AEC	930	kWh
AZ	**Contact details**	Samsung Electronics, PO Box 12987, Blackrock, Co. Dublin, Ireland or Blackbushe Business Park, Yateley, Gu46 6GG, UK		

	Item (J)	Symbol (K)	Value (L)	Unit (M)
P	**Seasonal space heating energy efficiency**	η_s	138	%
R	**Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj**			
-	Tj = -7 °C	COPd (S)	2,16	-
-	Tj = +2 °C	COPd (S)	3,45	-
-	Tj = +7 °C	COPd (S)	4,57	-
-	Tj = +12 °C	COPd (S)	6,12	-
T	Tj = bivalent temperature	COPd (S)	1,96	-
U	Tj = operation limit temperature	COPd (S)	1,96	-
V	For air-to-water heat pumps Tj = -15 °C (if TOL < -20 °C)	COPd (S)	-	-
X	For air-to-water heat pumps: Operation limit temperature	TOL	-10	°C
Z	Cycling interval efficiency	COPcyc (AA)	-	-
AC	Heating water operating limit temperature	WTOL	-	°C
AE	**Supplementary heater**			
N	Rated heat output (*)	Psup	-	kW
AJ	Type of energy input	Electrical (AK)		
AL	**Other items**			
AO	For air-to-water heat pumps : Rated air flow rate, outdoors	-	5940	m^3/h (AP)
AS	For water-/brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	-	m^3/h (AP)
AT	**For heat pump combination heater**			
AV	Water heating energy efficiency	η_{wh}	110	%
AX	Daily fuel consumption	Q_{fuel}	-	kWh
AY	Annual electricity consumption	AEC	-	GJ

BA	(*) For heat pump space heaters and heat pump combination heaters, the rated that output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
BB	(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.
BC	1) Precautions as described in the installation/user manual must be taken when assembling, installing and maintaining this product.
BD	2) If you are a professional looking for information on non-destructive disassembly, dismantling and battery removability, please send an email to: erims.sec@samsung.com

DB68-08410A-03_MI_EHS R-32 MONO Space heater Erp_EU_EN_.indd 27 2020-03-16 오전 10:55:05

COMMISSION REGULATION (EU) No 813/2013 [I)]

ECODESIGN REQUIREMENTS FOR HEAT PUMP SPACE HEATERS AND HEAT PUMP COMBINATION HEATERS [II)]

A	Model(s) : AE120RXYDEG / AE260RNWMEG
B	Air-to-water heat pump : yes
C	Water-to-water heat pump : no
D	Brine-to-water heat pump : no
E	Low-temperature heat pump : no
F	Equipped with a supplementary heater : yes
G	Heat pump combination heater : yes
H	Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pump, parameters shall be declared for low-temperature application.
I	Parameters shall be declared for average climate conditions.

	Item (J)	Symbol (K)	Value (L)	Unit (M)
N	**Rated heat output(*)**	Prated (o)	12	kW
Q	**Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T j**			
-	Tj = -7 °C	Pdh	10,6	kW
-	Tj = +2 °C	Pdh	6,5	kW
-	Tj = +7 °C	Pdh	4,2	kW
-	Tj = +12 °C	Pdh	4,4	kW
T	Tj = bivalent temperature	Pdh	12,0	kW
U	Tj = operation limit temperature	Pdh	12,0	kW
V	For air-to-water heat pumps Tj = -15 °C (if TOL < -20 °C)	Pdh	-	kW
W	Bivalent temperature	Tbiv	-10	°C
Y	Cycling interval capacity for heating	Pcych	-	kW
AB	Degradation co-efficient (**)	Cdh	0,9	-
AD	**Power consumption in modes other than active mode**			
AF	Off mode	P_{OFF}	0,022	kW
AG	Thermostat-off mode	P_{TO}	0,022	kW
AH	Standby mode	P_{SB}	0,022	kW
AI	Crankcase heater mode	P_{CK}	0,000	kW
AL	**Other items**			
AM	Capacity control	variable (AN)		
AQ	Sound power level, indoors/ outdoors	L_{WA}	44/64	dB
AR	Emissions of nitrogen oxides	NOx	-	mg/kWh
AT	**For heat pump combination heater**			
AU	Declared load profile	XL		
AW	Daily electricity comsumption	Q_{elec}	-	kWh
AY	Annual electricity consumption	AEC	1432	kWh
AZ	**Contact details**	Samsung Electronics, PO Box 12987, Blackrock, Co. Dublin, Ireland or Blackbushe Business Park, Yateley, Gu46 6GG, UK		

	Item (J)	Symbol (K)	Value (L)	Unit (M)
P	**Seasonal space heating energy efficiency**	η_s	138	%
R	**Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj**			
-	Tj = -7 °C	COPd (S)	2,16	-
-	Tj = +2 °C	COPd (S)	3,45	-
-	Tj = +7 °C	COPd (S)	4,57	-
-	Tj = +12 °C	COPd (S)	6,12	-
T	Tj = bivalent temperature	COPd (S)	1,96	-
U	Tj = operation limit temperature	COPd (S)	1,96	-
V	For air-to-water heat pumps Tj = -15 °C (if TOL < -20 °C)	COPd (S)	-	-
X	For air-to-water heat pumps: Operation limit temperature	TOL	-10	°C
Z	Cycling interval efficiency	COPcyc (AA)	-	-
AC	Heating water operating limit temperature	WTOL	-	°C
AE	**Supplementary heater**			
N	Rated heat output (*)	Psup	-	kW
AJ	Type of energy input	Electrical (AK)		
AL	**Other items**			
AO	For air-to-water heat pumps : Rated air flow rate, outdoors	-	5940	m^3/h (AP)
AS	For water-/brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	-	m^3/h (AP)
AT	**For heat pump combination heater**			
AV	Water heating energy efficiency	η_{wh}	117	%
AX	Daily fuel consumption	Q_{fuel}	-	kWh
AY	Annual electricity consumption	AEC	-	GJ

BA	(*) For heat pump space heaters and heat pump combination heaters, the rated that output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
BB	(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.
BC	1) Precautions as described in the installation/user manual must be taken when assembling, installing and maintaining this product.
BD	2) If you are a professional looking for information on non-destructive disassembly, dismantling and battery removability, please send an email to: erims.sec@samsung.com

DB68-08410A-03_MI_EHS R-32 MONO Space heater Erp_EU_EN_.indd 30 2020-03-16 오전 10:55:05

A	Model(s) : AE120RXYDEG
B	Air-to-water heat pump : yes
C	Water-to-water heat pump : no
D	Brine-to-water heat pump : no
E	Low-temperature heat pump : no
F	Equipped with a supplementary heater : yes
G	Heat pump combination heater : no
H	Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps. For low-temperature heat pump, parameters shall be declared for low-temperature application.
I	Parameters shall be declared for average climate conditions.

	Item (J)	Symbol (K)	Value (L)	Unit (M)
N	**Rated heat output(*)**	Prated (G)	12	kW
Q	**Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T j**			
-	Tj = -7 °C	Pdh	10,6	kW
	Tj = +2 °C	Pdh	6,5	kW
	Tj = +7 °C	Pdh	4,2	kW
	Tj = +12 °C	Pdh	4,4	kW
T	Tj = bivalent temperature	Pdh	12,0	kW
U	Tj = operation limit temperature	Pdh	12,0	kW
V	For air-to-water heat pumps Tj = -15 °C (if TOL < -20 °C)	Pdh	-	kW
W	Bivalent temperature	Tbiv	-10	°C
Y	Cycling interval capacity for heating	Pcych	-	kW
AB	Degradation co-efficient (**)	Cdh	0,9	-
AD	**Power consumption in modes other than active mode**			
AF	Off mode	P_{OFF}	0,022	kW
AG	Thermostat-off mode	P_{TO}	0,022	kW
AH	Standby mode	P_{SB}	0,022	kW
AI	Crankcase heater mode	P_{CK}	0,000	kW
AL	**Other items**			
AM	Capacity control	variable (AN)		
AQ	Sound power level, indoors/ outdoors	L_{WA}	-/64	dB
AR	Emissions of nitrogen oxides	NOx	-	mg/kWh
AT	**For heat pump combination heater**			
AU	Declared load profile	-		
AW	Daily electricity comsumption	Q_{elec}	-	kWh
AY	Annual electricity consumption	AEC	-	kWh
AZ	**Contact details**	Samsung Electronics, PO Box 12987, Blackrock, Co. Dublin, Ireland or Blackbushe Business Park, Yateley, Gu46 6GG, UK		

	Item (J)	Symbol (K)	Value (L)	Unit (M)
P	**Seasonal space heating energy efficiency**	η_s	138	%
R	**Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj**			
-	Tj = -7 °C	COPd (S)	2,16	-
	Tj = +2 °C	COPd (S)	3,45	-
	Tj = +7 °C	COPd (S)	4,57	-
	Tj = +12 °C	COPd (S)	6,12	-
T	Tj = bivalent temperature	COPd (S)	1,96	-
U	Tj = operation limit temperature	COPd (S)	1,96	-
V	For air-to-water heat pumps Tj = -15 °C (if TOL < -20 °C)	COPd (S)	-	-
X	For air-to-water heat pumps: Operation limit temperature	TOL	-10	°C
Z	Cycling interval efficiency	COPcyc (AA)	-	-
AC	Heating water operating limit temperature	WTOL	-	°C
AE	**Supplementary heater**			
N	Rated heat output (*)	Psup	-	kW
AJ	Type of energy input	Electrical (AK)		
AL	**Other items**			
AO	For air-to-water heat pumps : Rated air flow rate, outdoors	-	5940	m^3/h (AP)
AS	For water-/brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger	-	-	m^3/h (AP)
AT	**For heat pump combination heater**			
AV	Water heating energy efficiency	η_{wh}	-	%
AX	Daily fuel consumption	Q_{fuel}	-	kWh
AY	Annual electricity consumption	AEC	-	GJ

BA	(*) For heat pump space heaters and heat pump combination heaters, the rated that output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
BB	(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.
BC	1) Precautions as described in the installation/user manual must be taken when assembling, installing and maintaining this product.
BD	2) If you are a professional looking for information on non-destructive disassembly, dismantling and battery removability, please send an email to: erims.sec@samsung.com

DB68-08410A-03_MI_EHS R-32 MONO Space heater Erp_EU_EN_.indd 37 2020-03-16 오전 10:55:07

No	Danish(DA)	German(DE)	Estonian(ET)	Greek(EL)
I	KOMMISSIONENS FORORDNING (EU) Nr. 813/2013	VERORDNUNG (EU) Nr. 813/2013 DER KOMMISSION	KOMISJONI MÄÄRUS (EL) nr 813/2013,	ΚΑΝΟΝΙΣΜΌΣ (ΕΕ) αριθ. 813/2013 ΤΗΣ ΕΠΙΤΡΟΠΗΣ
II	ECODESIGN-KRAV TIL RUMOPVARMNINGSANLÆG OG KOMBINATIONSVARMEANLÆS MED VARMEPUMPER	ÖKODESIGN - ANFORDERUNGEN FÜR WÄRMEPUMPEN-RAUMHEIZUNGEN UND WÄRMEPUMPEN-KOMBINATIONSHEIZUNGEN	ÖKODISAINI NÕUDED SOOJUSPUMBAGA RUUMISOOJENDITELE JA SOOJUSPUMBAGA KOMBINEERITUD SOOJENDITELE	ΑΠΑΙΤΗΣΕΙΣ ΟΙΚΟΛΟΓΙΚΟΥ ΣΧΕΔΙΑΣΜΟΥ ΓΙΑ ΘΕΡΜΑΝΤΗΡΕΣ ΧΩΡΟΥ ΑΝΤΛΙΑΣ ΘΕΡΜΟΤΗΤΑΣ ΚΑΙ ΘΕΡΜΑΝΤΗΡΕΣ ΣΥΝΔΥΑΣΜΕΝΗΣ ΛΕΙΤΟΥΡΓΙΑΣ ΑΝΤΛΙΑΣ ΘΕΡΜΟΤΗΤΑΣ
A	Model(ler): [Information, som identificerer den eller de modeller, som oplysningerne vedrører]	Modell(e): (Angaben zur Bestimmung des Modells/der Modelle, auf das/die sich die Angaben beziehen)	Mudel(id): [mudelit (mudeleid) iseloomustavad näitajad]	Μοντέλο(-α): [πληροφορίες για την ταυτοποίηση του μοντέλου (των μοντέλων) που αφορούν οι πληροφορίες]
B	Luft-vand-varmepumpe: [ja/nej]	Luft-Wasser-Wärmepumpe: (Ja/Nein)	Õhu-vee-soojuspump: [jah/ei]	Αντλία θερμότητας αέρα-νερού: [ναι/όχι]
C	Vand-vand-varmepumpe: [ja/nej]	Wasser-Wasser-Wärmepumpe: (Ja/Nein)	Vee-vee-soojuspump: [jah/ei]	Αντλία θερμότητας νερού-νερού: [ναι/όχι]
D	Brine-vand-varmepumpe: [ja/nej]	Sole-Wasser-Wärmepumpe: (Ja/Nein)	Soojuskandja-vee-soojuspump: [jah/ei]	Αντλία θερμότητας άλμης-νερού: [ναι/όχι]
E	Lavtemperaturvarmepumpe: [ja/nej]	Niedertemperatur-Wärmepumpe: (Ja/Nein)	Külma kliima soojuspump: [jah/ei]	Αντλία θερμότητας χαμηλής θερμοκρασίας: [ναι/όχι]
F	Udstyret med supplerende forsyningsanlæg: [ja/nej]	Mit Zusatzheizgerät: (Ja/Nein)	Koos lisakütteseadmega: [jah/ei]	Εξοπλισμένος με συμπληρωματικό θερμαντήρα: [ναι/όχι]
G	Varmepumpeanlæg til kombineret rum- og brugsvandsopvarmning: [ja/nej]	Kombiheizgerät mit Wärmepumpe: (Ja/Nein)	Soojuspumbaga veesoojendi-kütteseade: [jah/ei]	Θερμαντήρας συνδυασμένης λειτουργίας με αντλία θερμότητας: [ναι/όχι]
H	Parametre skal angives for middeltemperaturanvendelse, dog ikke for lavtemperaturvarmepumper. For lavtemperaturvarmepumper angives parametre for lavtemperaturanvendelse.	Die Parameter sind für eine Mitteltemperaturanwendung anzugeben, außer für Niedertemperatur-Wärmepumpen. Für Niedertemperatur-Wärmepumpen sind die Parameter für eine Niedertemperaturanwendung anzugeben.	Näitajad esitatakse keskmise temperatuuriga kasutuse kohta, välja arvatud külma kliima soojuspumbad. Külma kliima soojuspumpade näitajad esitatakse madalatemperatuurilise kasutuse kohta.	Δηλώνονται οι παράμετροι για εφαρμογή μέσης θερμοκρασίας, εξαιρουμένων των αντλιών θερμότητας χαμηλής θερμοκρασίας. Για τις αντλίες θερμότητας χαμηλής θερμοκρασίας δηλώνονται οι παράμετροι για εφαρμογή χαμηλής θερμοκρασίας.
I	Parametre skal angives for gennemsnitlige klimaforhold.	Die Parameter sind für durchschnittliche Klimaverhältnisse anzugeben:	Näitajad esitatakse keskmiste kliimatingimuste kohta.	Δηλώνονται οι παράμετροι για μέσες κλιματικές συνθήκες.
J	Element	Angabe	Näitaja	Χαρακτηριστικό
K	Symbol	Symbol	Tähis	Σύμβολο
L	Værdi	Wert	Väärtus	Τιμή
M	Enhed	Einheit	Ühik	Μονάδα
N	Nominel nytteeffekt (*)	Wärmenennleistung (*)	Nimisoojusvõimsus (*)	Ονομαστική θερμική ισχύς (*)
O	Prated	Prated	Prated	Prated
P	Årsvirkningsgrad ved rumopvarmning	Jahreszeitbedingte Raumheizungs-Energieeffizienz	Kütmise sesoonne energiatõhusus	Ενεργειακή απόδοση της εποχιακής θέρμανσης χώρου
Q	Angivet varmeydelse for dellast ved indetemperatur på 20 °C og udetemperatur på Tj	Angegebene Leistung für Teillast bei Raumlufttemperatur 20 °C und Außenlufttemperatur Tj	Esitatud soojusvõimsus ruumitemperatuurile 20 °C ja välistemperatuurile Tj vastaval (osalise koormuse) võimsustarbel	Δηλωμένη θερμαντική ισχύς για μερικό φορτίο σε θερμοκρασία εσωτερικού χώρου 20 °C και θερμοκρασία εξωτερικού χώρου Tj
R	Angivet effektfaktor eller primærenergi-effektfaktor for dellast ved indetemperatur på 20 °C og udetemperatur på Tj	Angegebene Leistungszahl oder Heizzahl für Teillast bei Raumlufttemperatur 20 °C und Außenlufttemperatur Tj	Esitatud soojustegur (primaarenergiategur) ruumitemperatuurile 20 °C ja välistemperatuurile Tj vastaval (osalise koormuse) võimsustarbel	Δηλωμένος συντελεστής απόδοσης ή λόγος πρωτογενούς ενέργειας σε θερμοκρασία εσωτερικού χώρου 20 °C και θερμοκρασία εξωτερικού χώρου Tj
S	COPd eller PERd	COPd oder PERd	COPd või PERd	COPd ή PERd
T	Tj = bivalenttemperatur	Tj = Bivalenztemperatur	Tj = tasakaalutemperatuur	Tj = δίτιμη θερμοκρασία
U	Tj = temperaturgrænse for drift	Tj = Betriebstemperaturgrenzwert	Tj = piirtöötemperatuur	Tj = οριακή θερμοκρασία λειτουργίας
V	For luft-vand-varmepumper: Tj = – 15 °C (hvis TOL < – 20 °C)	Für Luft-Wasser-Wärmepumpen: Tj = – 15 °C (wenn TOL < – 20 °C)	Õhu-vee-soojuspump: Tj = – 15 °C (kui TOL < – 20 °C)	Για αντλίες θερμότητας αέρα-νερού: Tj = – 15 °C (εάν TOL < – 20 °C)
W	Bivalenttemperatur	Bivalenztemperatur	Tasakaalutemperatuur	Δίτιμη θερμοκρασία
X	For luft-vand-varmepumper: Temperaturgrænse for drift	Für Luft-Wasser-Wärmepumpen: Betriebsgrenzwert-Temperatur	Õhu-vee-soojuspump: piirtöötemperatuur	Για αντλίες θερμότητας αέρα-νερού: Οριακή θερμοκρασία λειτουργίας
Y	Cyklusintervaldelse for opvarmning	Leistung bei zyklischem Intervall-Heizbetrieb	Tsükli soojusvõimsus	Θερμαντική ισχύς κατά τη διάρκεια ενός κύκλου
Z	Cyklusintervaldelse	Leistungszahl bei zyklischem Intervallbetrieb	Tsükli tõhusus või primaarenergiategur	Απόδοση κατά τη διάρκεια ενός κύκλου
AA	COPcyc eller PERcyc	COPcyc oder PERcyc	COPcyc või PERcyc	COPcyc ή PERcyc
AB	Koefficient for effektivitetstab (**)	Minderungsfaktor (**)	Kaotegur (**)	Συντελεστής υποβάθμισης (**)

DB68-08410A-03_MI_EHS R-32 MONO Space heater Erp_EU_EN_.indd 43 2020-03-16 오전 10:55:08

COMMISSION REGULATION (EU) No 813/2013 [1)]

No	Danish(DA)	German(DE)	Estonian(ET)	Greek(EL)
AC	Temperaturgrænse for vandopvarmning	Grenzwert der Betriebstemperatur des Heizwassers	Küttevee piirtöötemperatuur	Οριακή θερμοκρασία λειτουργίας για θέρμανση νερού
AD	Elforbrug i andre tilstande end aktiv tilstand	Stromverbrauch in anderen Betriebsarten als dem Betriebszustand	Võimsustarve ajal, kui seade ei ole aktiivses seisundis	Κατανάλωση ισχύος σε καταστάσεις πλην της ενεργού κατάστασης
AE	Supplerende forsyningsanlæg	Zusatzheizgerät	Lisakütteseade	Συμπληρωματικός θερμαντήρας
AF	Slukket tilstand	Aus-Zustand	Väljalülitatud seisund	Κατάσταση εκτός λειτουργίας
AG	Termostat fra-tilstand	Thermostat-aus-Zustand	Termostaadiga välja lülitatud seisund	Κατάσταση χωρίς λειτουργία θερμοστάτη
AH	Standbytilstand	Bereitschaftszustand	Ooteseisund	Κατάσταση αναμονής
AI	Krumtaphusopvarmningstilstand	Betriebszustand mit Kurbelgehäuseheizung	Kambrikütte seisund	Λειτουργία θερμαντήρα στροφαλοθαλάμου
AJ	Energiinputtype	Art der Energiezufuhr	Sisendenergia liik	Τύπος εισερχόμενης ενέργειας
AK	Elektrisk	Elektrische	Elektriliste	Ηλεκτρικός
AL	Andre elementer	Sonstige Angaben	Muud näitajad	Άλλα χαρακτηριστικά
AM	Ydelsesregulering	Leistungssteuerung	Võimsuse reguleerimine	Ρύθμιση ισχύος
AN	fast/variabel	fest/veränderlich	Muutumatu/muudetav	σταθερή/μεταβλητή
AO	For luft-vand-varmepumper: Nominel luftgennemstrømning, ude	Für Luft-Wasser-Wärmepumpen: Nenn-Luftdurchsatz, außen	Õhu-vee-soojuspump: õhu nimivooluhulk, väliskeskkonnas	Για αντλίες θερμότητας αέρα-νερού: Ονομαστική παροχή αέρα, εξωτερικού χώρου
AP	m^3/h	m^3/h	m^3/h	m^3/h
AQ	Lydeffektniveau, inde/ude	Schallleistungspegel, innen/außen	Müravõimsustase, siseruumis/väliskeskkonnas	Στάθμη ηχητικής ισχύος, εσωτερικού/εξωτερικού χώρου
AR	Emissioner af kvælstofilter	Stickoxidausstoß	Lämmastikoksiidide heide	Εκπομπές οξειδίων του αζώτου
AS	For vand/brine-vand-varmepumper: nominel brine- eller vandgennemstrømning, varmeveksler, ude	Für Wasser/Sole-Wasser-Wärmepumpen: Wasser- oder Sole-Nenndurchsatz	Vee-soojuskandja-vee-soojuspump: soojuskandja või vee nimivooluhulk, soojusvaheti väljas	Για αντλίες θερμότητας νερού-/άλμης-νερού: Ονομαστική παροχή άλμης ή νερού, εναλλάκτη θερμότητας εξωτερικού χώρου
AT	For varmepumpeanlæg til kombineret rum- og brugsvandsopvarmning:	Kombiheizgerät mit Wärmepumpe	Soojuspumbaga veesoojendi-kütteseade:	Για θερμαντήρα συνδυασμένης λειτουργίας με αντλία θερμότητας:
AU	Angivet forbrugsprofil	Angegebenes Lastprofil	Esitatud koormusprofiil	Δηλωμένο προφίλ φορτίου
AV	Energieffektivitet ved vandopvarmning	Warmwasserbereitungs-Energieeffizienz	Vee soojendamise kasutegur	Ενεργειακή απόδοση θέρμανσης νερού
AW	Dagligt elforbrug	Täglicher Stromverbrauch	Päevane elektrienergiatarve	Ημερήσια κατανάλωση ηλεκτρικής ενέργειας
AX	Dagligt brændselsforbrug	Täglicher Brennstoffverbrauch	Päevane kütteenergiatarve	Ημερήσια κατανάλωση καυσίμου
AY	Årligt elektricitetsforbrug	Jährlicher Energieverbrauch	Aastane elektritarve	Κατανάλωση ενέργειας σε ετήσια βάση
AZ	Kontaktoplysninger	Kontakt	Kontaktandmed	Στοιχεία επικοινωνίας
BA	(*) For varmepumpeanlæg til rumopvarmning og varmepumpeanlæg til kombineret rum- og brugsvandsopvarmning er den nominelle nytteeffekt Prated lig med den dimensionerende last for opvarmning Pdesignh, og den nominelle nytteeffekt for et supplerende forsyningsanlæg Psup er lig med den supplerende varmeydelse sup(Tj).	(*) Für Heizgeräte und Kombiheizgeräte mit Wärmepumpe ist die Wärmenennleistung Prated gleich der Auslegungslast im Heizbetrieb Pdesignh und die Wärmenennleistung eines Zusatzheizgerätes Psup gleich der zusätzlichen Heizleistung sup(Tj).	(*) Soojuspumbaga kütteseadmete ja soojuspumbaga veesoojendite-kütteseadmete nimisoojusvõimsus Prated on võrdne arvutusliku soojusvõimsusega Pdesignh, lisakütteseadme Psup nimisoojusvõimsus on võrdne lisakütteseadme soojusvõimsusega sup(Tj).	(*) Για θερμαντήρες χώρου με αντλία θερμότητας και θερμαντήρες συνδυασμένης λειτουργίας με αντλία θερμότητας, η ονομαστική θερμική ισχύς Prated ισούται με το θερμαντικό φορτίο σχεδιασμού Pdesignh , και η ονομαστική θερμική ισχύς του συμπληρωματικού θερμαντήρα Psup ισούται με τη συμπληρωματική θερμαντική ισχύ sup(Tj).
BB	(**) Hvis Cdh ikke bestemmes ved måling, er koefficienten for effektivitetstab som standard Cdh = 0,9.	(**) Wird der Cdh-Wert nicht durch Messung bestimmt, gilt für den Minderungsfaktor der Vorgabewert Cdh = 0,9.	(**) Kui tegur Cdh on määramata, võetakse vaikimisi Cdh = 0,9.	(**) Εάν ο Cdh δεν προσδιοριστεί με μέτρηση, ο εξ ορισμού συντελεστής υποβάθμισης είναι Cdh = 0,9.
BC	1) Du skal tage de forholdsregler, der er beskrevet i installations-/brugervejledningen, når du samler, installerer og vedligeholder dette produkt.	1) Beim Montieren, Installieren und Warten des Geräts müssen die im Installations-/Benutzerhandbuch beschriebenen Vorsichtsmaßnahmen eingehalten werden.	1) Seadme kokkupanekul, paigaldamisel ja hooldusel tuleb rakendada paigaldus-/kasutusjuhendis kirjeldatud ettevaatusabinõusid	1) Όταν συναρμολογείτε, εγκαθιστάτε και συντηρείτε αυτό το προϊόν, πρέπει να λαμβάνετε τις προφυλάξεις που περιγράφονται στο εγχειρίδιο εγκατάστασης/χρήσης.
BD	2) Send en e-mail til erims.sec@samsung.com., hvis du er en fagperson, som søger oplysninger om, hvordan enheden kan skilles ad og batteriet fjernes, uden at forårsage skade.	2) Wenn Sie ein Fachmann sind, der Informationen über die nicht-destruktive Demontage, Zerlegung und Batterieentnahmefähigkeit sucht, schreiben Sie bitte eine E-Mail an: erims.sec@samsung.com	2) Kui olete professionaal, kes soovib teavet mittepurustava lahtivõtmise, demonteerimise ja aku eemaldatavuse kohta, saatke e-kiri aadressile erims.sec@samsung.com.	2) Αν είστε επαγγελματίας και αναζητάτε πληροφορίες σχετικά με τη μη καταστροφική αποσυναρμολόγηση, την αποξήλωση και τη δυνατότητα αφαίρεσης της μπαταρίας στείλτε email στη διεύθυνση: erims.sec@samsung.com

DB68-08410A-03_MI_EHS R-32 MONO Space heater Erp_EU_EN_.indd 44 2020-03-16 오전 10:55:09